
From: [REDACTED]
To: [REDACTED]
Sent: 7/14/2021 1:03:41 PM
Subject: 1300 Dixie Fire Ops update

Lead: IC [REDACTED] GCC

10:58 230kv Caribou-Table Mtn relayed. 11,006 customers out. As of 1300, all 4 generators at Caribou are back in service. Restoration efforts continue with the expectation that other 60kv lines back.

[REDACTED]: No updates. Awaiting air patrol.

[REDACTED], DCC: Only one small distribution move available.

[REDACTED]/PSS: Fire update: Dixie Fire now 2,000+ acres. Push E/NE along the rim. Paralleling the 230kv line. Expect impact to several transmission towers, but not a huge impact so far to our facilities. Burning away from Concow, Pulga and Cresta.

Action item: Continue to build out transmission island. Goal is to have that done "within an hour or so."

[REDACTED] Be safe.

[REDACTED]
PG&E Operations Communications

[REDACTED]
www.pge.com/wildfiresafety
www.pge.com/covid19